



DEPARTMENT OF ADMINISTRATIVE SERVICES

I-08-19

July 15, 2019

Mr. Craig Perreault, Northeast Sales Manager
Protecto Wrap Company
58 Chasehill Road
Andover, NH 03216

Re: Interpretation of 2018 CT State Building Code IRC Section R905.1.1
Roof Underlayment Systems

Mr. Perreault,

In your letter dated June 27, 2019 you requested a formal interpretation regarding whether the use of the Protecto Wrap Jiffy Seal Ice and Water Guard Extreme system complies with the requirements of section R905.1.1 of the 2015 IRC portion of the 2018 Connecticut State Building Code.

Answer:

Along with your letter you provided IAPMO evaluation report – ER-613. While this office does not approve or endorse specific products we do recognize independent evaluation reports. ER-613 states that the Jiffy Seal Ice and Water system when installed per the manufacturer's installation instructions and conditions of the report, complies with chapter 9 of the 2015 IRC.

Therefore, based on this evaluation, Jiffy Seal system would comply with 2015 IRC portion of the 2018 CT State Building Code including the CT amended section R905.1.1.

Sincerely,

A handwritten signature in blue ink, appearing to read "JCassidy", is written over the printed name.

Joseph V. Cassidy, P.E.
State Building Inspector